

MICHIGAN DEPARTMENT OF CONSUMER & INDUSTRY SERVICES  
**FIRE SAFETY COMPLIANCE RECORD**  
 (For Large/Small/Secure Child Caring Institutions)

DISTRIBUTION  
 PART 1- Licensing Consultant  
 PART 2- Inspecting Agency  
 PART 3- Applicant/Licensee

FACILITY/BUILDING NAME		FACILITY TYPE <input type="checkbox"/> Large (16-up) <input type="checkbox"/> Small (7 to 15) <input type="checkbox"/> Secure		LICENSE NUMBER
INSTITUTION NAME		CAPACITY	BEHAVIOR MANAGEMENT ROOM <input type="checkbox"/> Yes <input type="checkbox"/> No	STATUS
INSTITUTION ADDRESS (Number & Street)		REASON FOR INSPECTION		
CITY/VILLAGE	ZIP CODE	<input type="checkbox"/> Original <input type="checkbox"/> Follow-up	<input type="checkbox"/> Renewal <input type="checkbox"/> Complaint	<input type="checkbox"/> Interim <input type="checkbox"/> Other

THE STATEMENTS WHICH APPEAR OPPOSITE EACH RULE NUMBER ARE BRIEF SUMMARIES AND ARE NOT IDENTICAL TO THE ADMINISTRATIVE RULE. THE COLUMNS ARE TO INDICATE WHETHER THE BUILDING IS DETERMINED TO BE IN COMPLIANCE, OR IN NON-COMPLIANCE OR NOT APPLICABLE (N/A) WITH THE RULES. Each time that the non-compliance column is marked, please comment using Form BRS-1568.

RULE	TYPE OF CHILD CARING INSTITUTION								
	LARGE			SMALL			SECURE		
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A
<b>Rule 506 Fire drills and telephone.</b> (1) There shall be quarterly fire drills for each staff shift. Two drills shall include evacuation unless approved in writing as contraindicated. Drills shall be conducted at different times of day and night where there are 24 hour staff shifts. Records shall be maintained of drills giving date, time, and where evacuation was part of the drill, the approximate evacuation time .....									
(2) Telephone or other suitable means of communicating alarm of fire to the fire department shall be provided. Telephone numbers of the fire department shall be posted by all telephones .....									
<b>Rule 508 Facility location.</b> New and converted facilities shall not be established within 300 feet of an above ground storage tank containing flammable liquids used in connection with bulk plants, marine terminals, aircraft refueling, or similar hazards .....									
<b>Rule 510 Facilities with sleeping rooms above second floor.</b> All facilities with sleeping rooms above the second floor shall comply with the requirements of a secure facility with the exception of Rule 522(c) .....									
<b>Rule 512 Combustible materials and decorations.</b> (1) A facility shall be kept free of all combustible materials not necessary for operation .....									
(2) Combustible decorations are not permitted in a facility with the exception of personal artwork and decorations of residents are permitted up to 6 square feet of wall space in areas other than means of egress and hazardous areas .....									
<b>Rule 513 Basements as sleeping rooms prohibited.</b> A basement shall not be used as a sleeping room .....									
<b>Rule 515 Electrical.</b> Newly constructed, converted or remodeled facilities shall have electrical wiring and equipment installed in accordance with provisions of the NFPA pamphlet no. 70, 1978. An electrical certificate of approval shall be obtained from a qualified electrical inspection authority .....									

FACILITY/BUILDING NAME		LICENSE NUMBER							
RULE	TYPE OF CHILD CARING INSTITUTION								
	LARGE			SMALL			SECURE		
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A
(2) In existing facilities, electrical wiring equipment acceptable at the time these rules take effect shall continue to be approved until the facility or portion thereof is remodeled or converted. When a portion is remodeled or converted only the portion remodeled or converted need comply with subrule (1) of this rule. The electrical service shall be maintained in a safe condition. When conditions indicate a need for electrical inspection, an inspection shall be required and a copy shall be maintained at the facility. Any deficiencies noted in the inspection shall be corrected and a new electrical inspection shall be obtained .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 517 Facility construction.</b>									
(1) A new, substantially remodeled or converted large or secure facility shall be one of the following types of construction per NFPA pamphlet no. 220, 1979:									
(a) Type I 443 or 332 or type II 222 .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(b) Type II 111, type III 211, type IV 2HH, or type VIII up to 2 stories. A basement and second story of these types of construction require complete sprinkler protection .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(c) Type II 000, type III 200, or V 000 up to 2 stories with all stories completely covered by sprinkler protection .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) New, converted, and substantially remodeled small facilities shall be at least frame construction and shall be fire stopped at all wall and floor junctures and all wall and ceiling junctures with not less than 2 inch nominal lumber .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
<b>Rule 520 Interior finish.</b>									
(4) Paints or coatings containing, plastics, polyurethane, or epoxies may be used on noncombustible surfaces without proof of classification if not applied in excess of 8 mils, wallpaper may be 1/28 of an inch in thickness .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(5) In newly constructed, remodeled or converted facilities, interior finish classifications shall be that of the basic material without regard to subsequently applied paint or other covering in an attempt to meet classification .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(6) In existing facilities where the interior finish does not comply with subrule (5) and where the interior finish is applied to or not furred out more than 1 inch from a continuous noncombustible backing, the interior finish may be protected by an approved fire retardant coating so as to meet the interior finish requirements .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(7) Interior finish materials shall be as follows:									
(a) In small and large open facilities without a sprinkler system, class A or B in exitways and class A in behavior management rooms and class C in all others areas .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(b) In open facilities with a sprinkler system, at least class C throughout except in behavior management room .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(c) In secure facilities, class A throughout .....							<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 522 Fire protection.</b>									
Fire protection shall be provided in all facilities as follows:									
(a) In a small facility an attendant who is awake, dressed, and on duty 24 hours a day; complete sprinkler protection or compliance with Rule 523 .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(b) In a large facility an attendant who is awake, dressed, and on duty 24 hours a day; complete sprinkler protection or compliance with Rule 524 .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						

FACILITY/BUILDING NAME		LICENSE NUMBER							
RULE	TYPE OF CHILD CARING INSTITUTION								
	LARGE			SMALL			SECURE		
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A
(c) In a secure facility an attendant who is awake, dressed, and on duty 24 hours a day .....							<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 523 Fire detection; small facilities.</b>									
(1) Newly constructed, remodeled or converted small facilities electing to provide fire protection by fire detection shall be protected throughout by at least battery operated ionization fire detection devices in all sleeping rooms and areas except kitchens and bathrooms. Detection devices shall comply with the following:									
(a) Be listed and labeled by a nationally recognized testing laboratory .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(b) Be installed in accordance with manufacturer's and test specifications .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(c) Be cleaned and tested quarterly with a record of the cleaning and testing .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(d) Provide a signal when batteries are not providing sufficient power and when batteries are missing .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(2) Devices required by subrule (1) which signal low power or battery missing shall be immediately restored to full power. There shall be at least a 10% supply of extra batteries maintained at the facility for the total number of battery operated devices in the facility .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(3) In existing small facilities, detection approved before these rules take effect shall continue to be approved until the facility or portion thereof is remodeled or converted. The existing detection system shall be maintained in proper working order and tested at least quarterly with a record maintained of the testing .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
<b>Rule 524 Fire detection; large facilities</b>									
(1) In newly constructed, remodeled or converted large facilities electing to provide protection by detection shall be equipped with a 100% coverage fire detection system, tested and listed by nationally recognized, testing laboratory, installed in compliance with NFPA pamphlet no. 72A, 1979, NFPA pamphlet No. 72E, 1978, and these rules except that wiring and equipment shall comply with NFPA pamphlet No. 70, 1978 .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						
(2) In new, remodeled or converted large facilities the power supply for the automatic detection system shall be from an electric utility and shall be on a separate circuit fuse ahead of the main building service switch. A secondary power supply shall be provided which will maintain the system in operation in the event of a fire and will sound the alarm signaling units for a five minute period .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						
(3) In a new, remodeled or converted large facility where an automatic detection system is required the devices shall comply with the following provisions:									
(a) Be installed in all areas other than small bathrooms containing a single water closet and lavatory, small closets less than 20 square feet and similar spaces. Devices shall be spaced per recommendation of the manufacturer .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						
(b) Shall be smoke detectors, except heat detectors may be installed in attics, kitchens, bathrooms, attached garages, and heat plant rooms. Heat detectors shall be fixed temperature rate of rise .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						
(4) In a new, remodeled or converted facility, an automatic fire detection system shall be an electrical, closed circuit, self-supervised system which gives a signal in a staff-occupied area when trouble occurs in the system including loss of power supply .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>						

FACILITY/BUILDING NAME						LICENSE NUMBER				
RULE	TYPE OF CHILD CARING INSTITUTION									
	LARGE			SMALL			SECURE			
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	
(6) In existing large facilities, fire detection approved before these rules take effect shall continue to be approved until the facility is converted or a portion thereof is remodeled .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(7) Automatic detection systems, fire alarm systems, and fire detection systems shall be maintained in proper working condition. When problems occur they shall be immediately remedied. When a system is rendered inoperable staff shall be awake and on duty until the system is again operable .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 527 Sprinkler systems.</b>										
(1) A required sprinkler system in a new or converted facility shall comply with NFPA pamphlet no. 13, 1980. Where there is no adequate water from a community water system and the area to be protected exceeds 20,000 square feet a special pressure tank supplying water for the sprinklers shall be provided as per NFPA pamphlet no. 22, 1978. The tank shall be enclosed in at least a hour fire resistant rated structure or room .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) All required sprinkler systems shall be inspected and tested and all other maintenance performed as specified in NFPA pamphlet no. 13A. A record shall be maintained of these inspections .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(3) A sprinkler system in an existing facility approved before these rules take effect shall continue to be approved until the facility or portion thereof is remodeled, converted or expanded. The system shall be maintained in accordance with standards applicable at the time it was originally approved .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(4) Where an existing facility is remodeled or converted and the remodeling, conversion or expansion results in the existing sprinkler system not providing adequate protection, fire protection shall be provided by extension of the current system where it is possible or a new sprinkler system shall be installed in the affected area .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(5) Sprinkler piping for an isolated hazardous area which can be adequately protected by not more than 2 sprinklers may be connected directly to the domestic water supply at a point where a minimum 1 inch supply is available. An approved OS and Y valve and check valve shall be installed .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 532 Fire extinguishers.</b>										
(1) All required fire extinguishers shall be maintenance checked once a year with a tag or label attached indicating the month and year and identifying the person or company performing the service .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) All required extinguishers shall be recharged after use .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(3) A minimum of 1 approved extinguisher shall be provided for each floor and immediately adjacent to kitchens, combustible-type heating devices, and incinerators. Additional extinguishers may be required to assure that it is not necessary to travel more than 75 feet to an extinguisher .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(4) Extinguishers shall be mounted with the bottom at least 4 inches off the floor with the tops no higher than 5 feet off the floor. Where programmatically indicated the required extinguishers may be behind locked doors clearly labeled "Fire Extinguisher" if all staff carry keys to the doors .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(5) In new, remodeled or converted facilities extinguishers shall be at least 2-A10-B:C .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(6) In existing facilities previously approved extinguishers will continue to be approved if they are maintained in the area for which they were approved .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

FACILITY/BUILDING NAME	LICENSE NUMBER
------------------------	----------------

RULE	TYPE OF CHILD CARING INSTITUTION								
	LARGE			SMALL			SECURE		
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A
<b>Rule 535 Fire alarm.</b>									
(1) All new and converted large and secure facilities shall have a fire alarm with fire alarm pull stations at each exit on each floor .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) All new and converted small facilities with residents sleeping only on one floor shall have at least a fire alarm device. Such facilities with sleeping on more than one floor shall have a fire alarm system with at least 1 pull station on each level .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(3) Fire alarm systems and devices in existing facilities shall be maintained in proper working order and shall continue to be approved until the facility is remodeled or converted .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 538 Means of egress.</b>									
(1) All required means of egress shall be maintained in an unobstructed easily traveled condition .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) In existing facilities each resident occupied room shall have access to at least two independent properly separated approved means of egress or have a door leading directly to the outside at grade .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(3) In multi-story secure and large facilities at least one of the means of egress from each floor shall be direct to the outside or shall be through an enclosed stairway separated from exposure from the floors below and which exits directly to the outside at grade or a previously approved escape window .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(4) In a small facility where ambulatory residents use a floor above the street level one of the two required means of egress may be an approved escape window from each resident occupied room providing direct access to the ground with a sill height not more than five feet above the ground or which provides access to an approved fire escape .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(5) In newly constructed, remodeled or converted facilities each resident occupied story including a resident occupied basement, shall have not less than two independent approved means of egress separated by not less than 50% of the longest dimension of the story. Resident sleeping rooms where possible shall be located between approved means of egress. Where not possible each exit shall be arranged so no corridor or aisle has a pocket or dead end exceeding 20 feet with not more than 4 residents having sleeping rooms with exit access on such a corridor. There shall be no hazardous areas on dead-end corridors or aisles .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(6) In newly constructed, remodeled or converted large or secure facilities additional means of egress shall be required if the maximum possible occupancy exceeds 100 residents per story. There shall be at least one additional means of egress in such cases for each additional 100 residents. The additional means of egress shall be such that it is not necessary to travel more than 100 feet from the door of a resident occupied room to reach the nearest approved protected exitway from that story .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(7) An elevator shall not be approved as a means of egress .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(8) Means of egress shall not be used to house residents or for storage of any kind and shall not be obstructed or hidden from view .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(9) Each required means of egress from floors where non-ambulatory residents are permitted shall discharge at grade or shall be equipped with a ramp which terminates at grade. The ramp shall not exceed 1 foot of rise in 12 feet of run and shall have sturdy handrails. There shall be sufficient room at grade to permit movement to a safe distance from the facility .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

FACILITY/BUILDING NAME						LICENSE NUMBER			
RULE	TYPE OF CHILD CARING INSTITUTION								
	LARGE			SMALL			SECURE		
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A
(10) In a small facility housing 1 or more non-ambulatory or wheelchair residents required exitways forming part of the means of egress from the portion of the facility housing such residents shall not be less than 48 inches wide in a new facility and not less than 44 inches wide in a converted facility with doors a minimum of 36 inches wide .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 540 Stairways, halls and corridors.</b>									
(1) In existing and small facilities all stairs and other vertical openings shall be enclosed with materials equal in fire resistance to the standard partition construction of the building, if such partition construction is at least standard lath and plaster. There shall be a 1 3/4 inch solid wood core door with self-closing device and latching hardware forming an effective fire and smoke separation or each sleeping room on the second floor shall be equipped with at least a 1 3/4 inch solid wood core door with latching hardware .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) In all new and converted large and secure facilities stairways shall be enclosed with materials of at least fire resistant rating specified by NFPA pamphlet no. 220, 1979, for the type of construction. All other vertical openings through floors shall be fire-stopped with like materials .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(3) Where a facility has 2 or fewer levels with both levels existing at grade, and where the elevation between levels does not exceed 4 feet, the building shall be considered 1 story and enclosure shall not be required between levels .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(4) Stairways in new and converted facilities shall have treads and risers of uniform height and width, with treads not less than 9 1/2 inches deep exclusive of nosing, and risers not more than 7 3/4 inches high .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(5) Stairs in new, remodeled and converted facilities shall change direction only by use of intermediate landings and not be variance in tread width. Sturdy and securely fastened handrails located between 30 and 34 inches measured vertically above the nose of the tread shall be provided .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(6) Stairs in existing facilities approved before these rules take effect shall continue to be approved until the building or portion thereof encompassing the stairway is remodeled .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(7) An outside stairway or fire escape used as part of an approved means of egress shall be protected against fire in the building by blank or closed walls directly under and for 6 feet in all directions. Stationary windows of wire glass are permitted .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(8) In newly constructed small facilities, halls, corridors, aisles and stairs used as part of a means of egress shall not be less than 44 inches wide and not less than 36 inches wide in converted small facilities except as required by rule 538(10) .....				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
(9) In newly constructed and converted large and secure facilities, halls, corridors and aisles used as part of an exitway shall be at least 5 feet wide and 90 inches in height, and stairs shall be not less than 4 feet wide .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 543 Doors.</b>									
(1) Doors to required means of egress shall comply with all of the following:									
(a) Be side-hinged and installed at floor level .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(b) Be not less than 36 inches wide in new converted large and secure facilities and new small facilities, and not less than 30 inches wide in remodeled and converted small facilities except as required by rule 538(10) .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

FACILITY/BUILDING NAME						LICENSE NUMBER			
RULE	TYPE OF CHILD CARING INSTITUTION								
	LARGE			SMALL			SECURE		
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A
(c) Be at least than 78 inches high in new, remodeled and converted facilities .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(d) In large and secure facilities doors shall be hung to swing in the direction of egress except doors to single-occupant rooms and bathrooms .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(e) Be equipped with at least knob-type, properly operating, approved, positive latching, non-locking against egress hardware except as where otherwise provided by subrule (2) of this rule and rule 545 .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) In secure facilities locking hardware is permitted if resident sleeping rooms are equipped with approved electric locks, or if there are staff present and awake, fully dressed, on duty, and in possession of keys to release residents .....							<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(3) Doors entering stairs and other vertical openings and doors to fire rated enclosures shall not be held in an open position at any time .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(4) Interior doors to an enclosure which is required to have not less than 1 hour fire resistant rating shall be B-labeled fire doors in labeled frames and shall be equipped with positive latching hardware and self-closing devices .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 545 Behavior management room.</b>									
(1) A behavior management room shall be approved in writing for such use by the fire inspecting authority and the licensing authority .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) A behavior management room shall be constructed to allow for both visual and auditory supervision of a resident .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(3) A behavior management room shall have walls and ceilings made of noncombustible materials .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(4) A behavior management room may have 1 approved locking against egress device on the door if a staff person is immediately present and awake and in possession of a key for the door locking device when the room is in use .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 546 Partition construction.</b>									
In new, remodeled or converted large and secure facilities rooms shall be separated from corridors used as a means of egress with partition construction which extends to the floor or deck above and which affords at least a 3/4 hour fire resistant rating. Doors shall be at least 1 3/4 solid wood core. Any glass in these partitions including door shall be wired glass not more than 54 inches in any one lineal dimension and not more than 1,296 square inches. This rule does not apply where the type of construction requires more restrictive separation .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Rule 548 Large and secure facilities; lighting in means of egress.</b>									
(1) In large and secure facilities, halls, stairs and means of egress shall be constantly lighted. Exit signs shall be installed over each required exit. Exit directional signs shall be provided where exits are not readily visible in means of egress. In new and converted large and secure facilities the circuits for this lighting shall be installed ahead of the main power disconnect .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
(2) In new and converted multiple story large and secure facilities there shall be a system of emergency backup capable of maintaining required lighting for not less than 24 hours in the event of a power failure .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

FACILITY/BUILDING NAME						LICENSE NUMBER			
RULE	TYPE OF CHILD CARING INSTITUTION								
	LARGE			SMALL			SECURE		
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A
<b>Rule 550 Elevators and dumbwaiters.</b> Elevator and dumbwaiter shafts shall be completely enclosed by noncombustible materials with a fire resistant rating of not less than 1 hour. Doors and frames servicing elevators and dumbwaiters shall be B-labeled fire doors and installed in labeled fire frame construction and shall be reasonably smoke tight when the doors are closed. Glass side lights, transoms, and panels above the doors shall be wire glass and not exceed 100 square inches .....									
<b>Rule 552 Heating devices and flame producing devices.</b> (1) In large and secure facilities and all newly constructed and converted facilities, flame producing type heating devices and incinerators shall be in at least 1 hour fire resistant enclosure with adequate combustion air provided directly from the outside. Fire dampers are not required in ducts penetrating this enclosure .....									
(2) In existing small facilities, flame producing type heating devices and incinerators approved before these rules shall continue to be approved with regard to enclosure or lack of enclosure until the portion of the facility containing the flame producing device is remodeled. Doors and other safety device factors shall be maintained in proper working order .....									
(3) Electric heat shall be installed in accordance with the manufacturer's specifications and shall be of a type approved by a nationally independent testing laboratory .....									
(4) Portable heaters and space heaters, including solid fuel heaters, are prohibited .....									
(5) A fireplace is permitted if it is masonry and has an approved glass door shielding the opening and a noncombustible hearth extending 16 inches out front and 8 inches beyond each side of the fireplace opening and a noncombustible face extending at least 12 inches above and 8 inches to the side of the fireplace opening with masonry chimney constructed with approved flue liners .....									
(6) A heating plant room shall not be used for combustible storage or for a maintenance shop unless sprinklered .....									
(7) A furnace and other flame producing unit shall be installed in accordance with manufacturer's and test specifications and vented to a chimney which is constructed of bricks or solid masonry, or reinforced concrete which has an approved flue lining and is properly erected and maintained. A bracket chimney is not permitted. A prefabricated chimney bearing the label of nationally recognized testing laboratory installed and used in accordance with the manufacturer and test specifications is permissible if it is compatible with the heating unit or units connected to it. Only gas and oil fired units may be connected to a prefabricated chimney .....									
<b>Rule 554 Air handling equipment.</b> (1) In newly constructed or converted large or secure facilities air conditioning, warm air heating, air cooling, and ventilation systems shall comply with NFPA pamphlet no. 90A, 1978 .....									
(2) In newly constructed or converted large or secure facilities fan and air handling equipment used to recirculate in more than one area or room air shall have a thermostatic device with a setting of not more than 125 degrees Fahrenheit or an approved automatic smoke detector located at a suitable point in the return air duct ahead of the fresh air intake, the actuation of which shall open the electrical circuits supplying the fan motor. The fan room shall not be used for any other purpose except housing other mechanical equipment .....									



FACILITY/BUILDING NAME		LICENSE NUMBER								
RULE	TYPE OF CHILD CARING INSTITUTION									
	LARGE			SMALL			SECURE			
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	
(3) In existing facilities, fans and air handling equipment approved before these rules take effect shall continue to be approved. Such equipment shall be maintained in proper and safe working order .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Rule 555 Smoke barriers.</b>										
(1) Smoke barriers with a 1 hour fire resistant rating shall be provided on each floor used for sleeping rooms for more than 24 residents, and shall be so located as to form an area of refuge on either side that is served with an approved means of egress. Barriers shall be as close as possible to the middle of the floor and shall extend from the outside wall to outside wall from floor through any interstitial space to the roof or floor above .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(2) Doors in the smoke barrier shall be at least C label fire doors hung in labeled frames with self-closing devices. Where doors without mullions are used, synchronization hardware and astragals shall be installed .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(3) Doors in smoke barrier partition may be held open only by electric hold-open devices designed so that interruption electrical current or actuation of fire alarm, sprinkler system, or heat or smoke detector will cause the release of the doors. The doors shall also be capable of being opened and closed manually .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Rule 557 Storage rooms.</b>										
Storage rooms larger than 100 square feet used for storing combustible materials shall be separated from the rest of the building by construction of at least 1 hour fire resistant rating .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Rule 559 Combustible storage.</b>										
(1) In a new, remodeled, or converted large or secure facility hazardous areas and rooms for storage of combustibles, including janitor rooms and closets except as provided by subrule (2), linen rooms except as provided by subrule (2), shipping and receiving rooms, kitchens, storage rooms, and maintenance shops shall be separated from the remainder of the building by at least 1 hour fire resistant construction and shall be protected by automatic sprinklers .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(2) In a new, remodeled or converted large or secure facility, janitor rooms, closets and linen rooms of less than 21 square feet do not require automatic sprinklers when located on a corridor or in an area not used as part of a required means of egress or where these rooms or closets are not on an egress corridor or where these rooms and closets are on an egress corridor and the door to such is a B labeled fire door and labeled frame .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(3) In existing facilities, combustible materials storage rooms and hazardous areas including janitor rooms and closets, shipping and receiving rooms, kitchen storage rooms, and maintenance shops approved before these rules take effect shall continue to be approved until the facility or portion thereof is remodeled .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Rule 560 Cooking appliances.</b>										
(1) Cooking appliances shall be suitably installed in accordance with approved safety practices .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(2) Where metal hoods or canopies are provided over domestic cooking appliances they shall be equipped with filters which are maintained in an efficient and clean condition .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

FACILITY/BUILDING NAME						LICENSE NUMBER			
RULE	TYPE OF CHILD CARING INSTITUTION								
	LARGE			SMALL			SECURE		
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A
<p>(3) In a newly constructed, remodeled or converted large and secured facility metal hoods or canopies over commercial cooking appliances, they shall be designed and equipped in compliance with NFPA pamphlet no. 96, 1980, and comply with the following:</p> <p>(a) Filters shall be maintained in efficient and clean condition .....</p> <p>(b) Only vaporproof electrical wiring and equipment shall be permitted in hoods or canopies .....</p> <p>(c) Exhaust ducts from hoods which run through open spaces between a ceiling and a floor or roof or through any floor above, shall be enclosed in 2 hour fire resistant construction .....</p> <p>(d) Fire extinguishing equipment for the hood and exhaust duct of a cooking appliance shall comply with NFPA pamphlet no. 96, 1980 .....</p> <p>(4) In existing facilities metal hoods and canopies approved before these rules take effect shall continue to be approved until the portion of the facility which incorporates the kitchen is remodeled or converted. Filters in any such hood or canopy shall be maintained in an efficient and clean condition .....</p>									
<p><b>Rule 562 Rubbish handling and incinerators.</b></p> <p>(1) In newly constructed, remodeled or converted large or secure facilities rubbish handling and incinerators shall comply with NFPA pamphlet no. 82, 1977. Rubbish chutes and refuse bins or rooms shall comply with the provisions of this pamphlet for industrial type incinerators. Approved 2 bushel or less gas incinerators may be placed in an approved furnace room and shall be equipped with an approved automatic 100% shutoff control. Feeder doors shall be located in an enclosed sprinklered room or compartment separated from other parts of the building by at least 1 hour fire resistant construction with openings to such rooms or compartments protected by approved B-labeled fire door assembly and labeled fire frame .....</p> <p>(2) In newly constructed, remodeled or converted large or secure facilities rubbish chutes shall not extend less than 4 feet above the roof and shall be covered by a metal skylight glazed with thin-pane glass. Sprinkler heads shall be installed at the top of the rubbish chute and within the chutes at alternate floors in buildings or more than 2 stories. The rubbish shall enter into a separate room, closet or bin constructed of materials having at least 1 hour fire resistant rating and protected with automatic sprinkler system .....</p> <p>(3) In new construction incinerator rooms shall have at least 1 wall on an outside not exposing a closed court .....</p> <p>(4) In an existing large or secure facility rubbish handling and incinerators approved before these rules take effect shall continue to be approved until the portion of the facility which includes rubbish handling facilities or incinerators is remodeled .....</p>									
<p><b>Rule 563 Laundries.</b></p> <p>(1) In newly constructed, remodeled, or converted large or secure facilities with a laundry, the laundry shall comply with the following:</p> <p>(a) Be located in a room constructed of materials having at least 1 hour fire resistant rating with an approved automatic sprinkler system. When the laundry is located in a nonresident occupied level a sprinkler system is not required when domestic laundry equipment is used .....</p>									

FACILITY/BUILDING NAME		LICENSE NUMBER								
RULE	TYPE OF CHILD CARING INSTITUTION									
	LARGE			SMALL			SECURE			
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	
(b) Have steam lines installed with a 1 inch clearance from combustibles ..	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(c) Have dryers of metal. Lint traps shall be cleaned frequently .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(d) Have 100% automatic and manual shutoff controls for gas appliances other than domestic laundry equipment which need only have manual shutoff controls .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(e) Have adequate outside air for combustion .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(2) In a newly constructed, remodeled or converted facility, laundry chutes shall be in compliance with all of the following requirements:										
(a) Be enclosed in shafts of at least 1 hour fire resistant rating. If the shaft extends through the roof of the building the top of the shaft shall be covered with noncombustible material affording at least 1 hour fire resistant rating. There shall be no openings into the shaft other than those intended for the use of the laundry chute. Feeder doors shall be located in an enclosed sprinklered room or compartment separated from other parts of the building by walls, floors, and a ceiling having at least a 1 hour fire resistant rating. Doors to such rooms shall be B-labeled fire doors in labeled frames .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(b) A sprinkler head installed at the top of the chute and within the laundry chute at alternate floor levels in buildings over 2 stories .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(c) Empty into a separate room, closet or bin constructed of materials having at least 1 hour fire resistant rating and protected by automatic sprinklers .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(d) Have an open vent at the top where the shaft extends through the roof, a skylight glazed with ordinary glass which is not less than 10% of the shaft area, or a window of ordinary glass which is not less than 10% of the shaft area and which is set in the side of the shaft with the sill of the window not less than 2 feet above the roof and 10 feet from any property line or other exposure .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(3) In existing facilities laundry facilities and laundry chutes approved before these rules take effect shall continue to be approved until the facility is converted or a portion of the facility which includes the laundry facility or chute is remodeled .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Rule 564 Motor vehicle housing.</b> A motor vehicle or gasoline powered equipment or device which may cause or communicate fire and is not necessary for the personal care of residents shall not be stored within a facility unless the area housing such equipment is separated from the rest of the facility by materials having at least a 1 hour fire resistant rating .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Rule 566 Garages.</b> (1) Garages located beneath a facility shall have walls, partitions, floors and ceilings separating the garage space from the rest of the facility by construction of not less than 1 hour fire resistant rating .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(2) In newly constructed, remodeled or converted facilities a garage located beneath the facility shall be sprinklered .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(3) Garages attached to a facility shall be completely separate from the rest of the facility by construction with not less than 1 hour fire resistant rating .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
(4) In all new, remodeled or converted facilities the sills of all door openings between the garage and breezeway or garage and facility shall be at least 4 inches above the garage floor .....	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

FACILITY/BUILDING NAME						LICENSE NUMBER			
<b>RULE</b>	<b>TYPE OF CHILD CARING INSTITUTION</b>								
	<b>LARGE</b>			<b>SMALL</b>			<b>SECURE</b>		
	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A	Comp.	Non-Comp.	N/A
<p>(5) In existing facilities garages located beneath or attached to the facility approved before these rules take effect shall continue to be approved until the facility is converted or a portion of the facility containing the garage is remodeled .....</p> <p><b>Rule 568 Assemblage area.</b>  A resident use assemblage area in a newly constructed or converted facility shall comply with the requirements of R28.101 to R28.112 governing places of public assemblage. Each door of an assemblage area occupied by residents shall enter a corridor between exits or shall have direct egress to the outside. In existing facilities, assemblage areas approved before these rules take effect shall continue to be approved until the areas are remodeled or converted .....</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

### RECOMMENDATION

<p><b>RECOMMENDATION</b> (If you have any questions concerning this report, please contact the inspecting person named below).</p> <p>A. <input type="checkbox"/> This facility has been determined to be in substantial compliance.</p> <p>B. <input type="checkbox"/> Because of the above listed deficiencies, temporary approval is recommended until next renewal inspection and report.</p> <p>C. <input type="checkbox"/> Because of the above listed deficiencies, temporary approval is recommended until _____ (date).</p> <p>D. <input type="checkbox"/> This facility has been determined to be in substantial non-compliance. Approval is not recommended.</p>		
14. NAME OF INSPECTING PERSON (Print or type)		15. TELEPHONE NUMBER (     )
16. FACILITY ADDRESS (Number, Street)	CITY	ZIP CODE
17. SIGNATURE OF INSPECTING PERSON		18. DATE OF INSPECTION

<p><b>AUTHORITY:</b> P.A. 116 of 1973</p> <p><b>COMPLETION:</b> Required.</p> <p><b>CONSEQUENCE:</b> License may be denied.</p>	<p>The Department of Consumer &amp; Industry Services will not discriminate against any individual or group because of race, sex, religion, age, national origin, color, marital status, handicap, or political beliefs. If you need assistance with reading, writing, hearing, etc. under the Americans with Disabilities Act, you may make your needs known to this agency.</p>
---	---